



TECHNICAL BULLETIN

DISPOSITION OF FIRE EXTINGUISHER CYLINDERS THAT HAVE BEEN SUBJECTED TO EXCESS PRESSURE DURING HYDROSTATIC TESTING

In the event that a fire extinguisher cylinder is subjected to a hydrostatic test pressure greater than that specified on the extinguisher nameplate, or when the pressure is not specified on the nameplate, to a pressure greater than that specified by NFPA 10, Standard for Portable Fire Extinguishers, the cylinder shall be condemned or destroyed. Condemnation of the cylinder shall be accomplished in accordance with the requirements of NFPA 10.