



**TECHNICAL BULLETIN 01-16**

**July 21, 2016**

**Clarification of Service Manual #133911 for Nitrogen Cylinder Operated Regulated and Pressure Transfer Type Wheeled Dry Chemical Fire Extinguishers**

The Service Manual has been revised to note that the Agent Charge Verification Check (Reference Section III, Page 13, paragraph k and Page 16, paragraph n) of the Manual is a visual reference check and that any discrepancy is to be verified by weighing the extinguisher and verifying the weight by the gross weight stated on the extinguisher nameplate label. This revision applies to previous editions of the Service Manual and has been incorporated into the current Manual edition.